

## Key Performance Indicators - Monthly

**From**                      **1/07/2019**                      **To**                      **31/07/2019**

Parameter	Unit	Last	90 Percentile Concentration	MIN (90 Percentile Concentration)	MAX (90 Percentile Concentration)
BOD	mg/L	1.00	1.00	-	10
Chlorine (Free Residual)	mg/L	0.02	0.03	-	0.1
Faecal Coliforms	CFU/100ml	0.50	0.50	-	150
Nitrogen (Ammonia)	mg/L	0.02	0.02	-	2
Nitrogen (Total)	mg/L	4.32	4.38	-	10
Oil and Grease	mg/L	0.50	0.50	-	2
pH		7.90	7.90	6.5	8.0
Phosphorus (Total)	mg/L-P	0.02	0.02	-	0.5
Total Suspended Solids	mg/L	2.00	2.00	-	10

## Key Performance Indicators - 1st of the Year to End of the Month

**From**                      **1/01/2019**                      **To**                      **31/07/2019**

Parameter	Unit	Last	90 Percentile Concentration	MIN (90 Percentile Concentration)	MAX (90 Percentile Concentration)
BOD	mg/L	1.00	2.00	-	10
Chlorine (Free Residual)	mg/L	0.02	0.02	-	0.1
Faecal Coliforms	CFU/100ml	0.50	0.50	-	150
Nitrogen (Ammonia)	mg/L	0.02	0.20	-	2
Nitrogen (Total)	mg/L	4.32	5.69	-	10
Oil and Grease	mg/L	0.50	0.50	-	2
pH		7.90	8.07	6.5	8.0
Phosphorus (Total)	mg/L-P	0.02	0.14	-	0.5
Total Suspended Solids	mg/L	2.00	10.00	-	10