

## Key Performance Indicators - Monthly

| Key Performance Indicators - Monthly |           |      |                             |                                   |                                   |
|--------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                      |           | From | 1/07/2017                   | To                                | 31/07/2017                        |
|                                      | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                  | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)             | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                     | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                   | mg/L-N    | 1.18 | 1.18                        | -                                 | 2                                 |
| Nitrogen (Total)                     | mg/L-N    | 5.72 | 5.74                        | -                                 | 10                                |
| Oil and Grease                       | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                   |           | 7.49 | 7.65                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                   | mg/L-P    | 0.02 | 0.03                        | -                                 | 0.5                               |
| Total Suspended Solids               | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |

## Key Performance Indicators - 1st of the Year to End of the Month

| Key Performance Indicators - 1st of the Year to End of the Month |           |      |                             |                                   |                                   |
|------------------------------------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                                                  |           | From | 1/01/2017                   | To                                | 31/07/2017                        |
|                                                                  | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                                              | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)                                         | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                                                 | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                                               | mg/L-N    | 1.18 | 0.77                        | -                                 | 2                                 |
| Nitrogen (Total)                                                 | mg/L-N    | 5.72 | 5.00                        | -                                 | 10                                |
| Oil and Grease                                                   | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                                               |           | 7.49 | 7.72                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                                               | mg/L-P    | 0.02 | 0.16                        | -                                 | 0.5                               |
| Total Suspended Solids                                           | mg/L      | 1.00 | 3.50                        | -                                 | 10                                |

## Key Performance Indicators - Monthly

| Key Performance Indicators - Monthly |           |      |                             |                                   |                                   |
|--------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                      |           | From | 1/08/2017                   | To                                | 31/08/2017                        |
|                                      | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                  | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)             | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                     | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                   | mg/L-N    | 0.39 | 1.78                        | -                                 | 2                                 |
| Nitrogen (Total)                     | mg/L-N    | 4.40 | 5.69                        | -                                 | 10                                |
| Oil and Grease                       | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                   |           | 7.72 | 7.72                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                   | mg/L-P    | 0.02 | 0.03                        | -                                 | 0.5                               |
| Total Suspended Solids               | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |

## Key Performance Indicators - 1st of the Year to End of the Month

| Key Performance Indicators - 1st of the Year to End of the Month |           |      |                             |                                   |                                   |
|------------------------------------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                                                  |           | From | 1/01/2017                   | To                                | 31/08/2017                        |
|                                                                  | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                                              | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)                                         | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                                                 | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                                               | mg/L-N    | 0.39 | 1.09                        | -                                 | 2                                 |
| Nitrogen (Total)                                                 | mg/L-N    | 4.40 | 5.53                        | -                                 | 10                                |
| Oil and Grease                                                   | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                                               |           | 7.72 | 7.72                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                                               | mg/L-P    | 0.02 | 0.16                        | -                                 | 0.5                               |
| Total Suspended Solids                                           | mg/L      | 1.00 | 3.50                        | -                                 | 10                                |

## Key Performance Indicators - Monthly

| Key Performance Indicators - Monthly |           |      |                             |                                   |                                   |
|--------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                      |           | From | 1/09/2017                   | To                                | 30/09/2017                        |
|                                      | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                  | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)             | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                     | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                   | mg/L-N    | 0.03 | 0.51                        | -                                 | 2                                 |
| Nitrogen (Total)                     | mg/L-N    | 5.30 | 5.30                        | -                                 | 10                                |
| Oil and Grease                       | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                   |           | 7.65 | 7.65                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                   | mg/L-P    | 0.02 | 0.02                        | -                                 | 0.5                               |
| Total Suspended Solids               | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |

## Key Performance Indicators - 1st of the Year to End of the Month

| Key Performance Indicators - 1st of the Year to End of the Month |           |      |                             |                                   |                                   |
|------------------------------------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                                                  |           | From | 1/01/2017                   | To                                | 30/09/2017                        |
|                                                                  | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                                              | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)                                         | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                                                 | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                                               | mg/L-N    | 0.03 | 1.00                        | -                                 | 2                                 |
| Nitrogen (Total)                                                 | mg/L-N    | 5.30 | 5.37                        | -                                 | 10                                |
| Oil and Grease                                                   | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                                               |           | 7.65 | 7.72                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                                               | mg/L-P    | 0.02 | 0.15                        | -                                 | 0.5                               |
| Total Suspended Solids                                           | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |

## Key Performance Indicators - Monthly

| Key Performance Indicators - Monthly |           |      |                             |                                   |                                   |
|--------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                      |           | From | 1/10/2017                   | To                                | 31/10/2017                        |
|                                      | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                  | mg/L      | 1.00 | 2.00                        | -                                 | 10                                |
| Chlorine (Free Residual)             | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                     | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                   | mg/L-N    | 0.03 | 0.04                        | -                                 | 2                                 |
| Nitrogen (Total)                     | mg/L-N    | 5.53 | 6.82                        | -                                 | 10                                |
| Oil and Grease                       | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                   |           | 7.06 | 7.65                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                   | mg/L-P    | 0.02 | 0.03                        | -                                 | 0.5                               |
| Total Suspended Solids               | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |

## Key Performance Indicators - 1st of the Year to End of the Month

| Key Performance Indicators - 1st of the Year to End of the Month |           |      |                             |                                   |                                   |
|------------------------------------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                                                  |           | From | 1/01/2017                   | To                                | 31/10/2017                        |
|                                                                  | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                                              | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)                                         | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                                                 | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                                               | mg/L-N    | 0.03 | 0.77                        | -                                 | 2                                 |
| Nitrogen (Total)                                                 | mg/L-N    | 5.53 | 5.61                        | -                                 | 10                                |
| Oil and Grease                                                   | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                                               |           | 7.06 | 7.72                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                                               | mg/L-P    | 0.02 | 0.12                        | -                                 | 0.5                               |
| Total Suspended Solids                                           | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |

## Key Performance Indicators - Monthly

| Key Performance Indicators - Monthly |           |      |                             |                                   |                                   |
|--------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                      |           | From | 1/11/2017                   | To                                | 30/11/2017                        |
|                                      | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                  | mg/L      | 2.00 | 2.00                        | -                                 | 10                                |
| Chlorine (Free Residual)             | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                     | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                   | mg/L-N    | 0.04 | 0.05                        | -                                 | 2                                 |
| Nitrogen (Total)                     | mg/L-N    | 5.44 | 5.60                        | -                                 | 10                                |
| Oil and Grease                       | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                   |           | 7.71 | 7.89                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                   | mg/L-P    | 0.01 | 0.02                        | -                                 | 0.5                               |
| Total Suspended Solids               | mg/L      | 1.00 | 2.00                        | -                                 | 10                                |

## Key Performance Indicators - 1st of the Year to End of the Month

| Key Performance Indicators - 1st of the Year to End of the Month |           |      |                             |                                   |                                   |
|------------------------------------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                                                  |           | From | 1/01/2017                   | To                                | 30/11/2017                        |
|                                                                  | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                                              | mg/L      | 2.00 | 1.50                        | -                                 | 10                                |
| Chlorine (Free Residual)                                         | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                                                 | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                                               | mg/L-N    | 0.04 | 0.77                        | -                                 | 2                                 |
| Nitrogen (Total)                                                 | mg/L-N    | 5.44 | 5.65                        | -                                 | 10                                |
| Oil and Grease                                                   | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                                               |           | 7.71 | 7.72                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                                               | mg/L-P    | 0.01 | 0.12                        | -                                 | 0.5                               |
| Total Suspended Solids                                           | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |

## Key Performance Indicators - Monthly

| Key Performance Indicators - Monthly |           |      |                             |                                   |                                   |
|--------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                      |           | From | 1/12/2017                   | To                                | 31/12/2017                        |
|                                      | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                  | mg/L      | 5.00 | 5.00                        | -                                 | 10                                |
| Chlorine (Free Residual)             | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                     | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                   | mg/L-N    | 0.02 | 0.02                        | -                                 | 2                                 |
| Nitrogen (Total)                     | mg/L-N    | 5.24 | 5.24                        | -                                 | 10                                |
| Oil and Grease                       | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                   |           | 7.74 | 7.84                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                   | mg/L-P    | 0.02 | 0.02                        | -                                 | 0.5                               |
| Total Suspended Solids               | mg/L      | 1.00 | 2.00                        | -                                 | 10                                |

## Key Performance Indicators - 1st of the Year to End of the Month

| Key Performance Indicators - 1st of the Year to End of the Month |           |      |                             |                                   |                                   |
|------------------------------------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                                                  |           | From | 1/01/2017                   | To                                | 31/12/2017                        |
|                                                                  | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                                              | mg/L      | 5.00 | 2.00                        | -                                 | 10                                |
| Chlorine (Free Residual)                                         | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                                                 | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                                               | mg/L-N    | 0.02 | 0.77                        | -                                 | 2                                 |
| Nitrogen (Total)                                                 | mg/L-N    | 5.24 | 5.65                        | -                                 | 10                                |
| Oil and Grease                                                   | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                                               |           | 7.74 | 7.74                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                                               | mg/L-P    | 0.02 | 0.12                        | -                                 | 0.5                               |
| Total Suspended Solids                                           | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |

**Key Performance Indicators - Monthly**

| <b>Key Performance Indicators - Monthly</b> |                  |             |                                    |                                          |                                          |
|---------------------------------------------|------------------|-------------|------------------------------------|------------------------------------------|------------------------------------------|
|                                             |                  | <b>From</b> | <b>1/01/2018</b>                   | <b>To</b>                                | <b>31/01/2018</b>                        |
|                                             | <b>Unit</b>      | <b>Last</b> | <b>90 Percentile Concentration</b> | <b>MIN (90 Percentile Concentration)</b> | <b>MAX (90 Percentile Concentration)</b> |
| <b>BOD</b>                                  | <b>mg/L</b>      | <b>2.00</b> | <b>3.00</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Chlorine (Free Residual)</b>             | <b>mg/L</b>      | <b>0.02</b> | <b>0.02</b>                        | <b>-</b>                                 | <b>0.1</b>                               |
| <b>Faecal Coliforms</b>                     | <b>CFU/100ml</b> | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>150</b>                               |
| <b>Nitrogen (Ammonia)</b>                   | <b>mg/L-N</b>    | <b>0.02</b> | <b>0.02</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>Nitrogen (Total)</b>                     | <b>mg/L-N</b>    | <b>5.29</b> | <b>5.29</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Oil and Grease</b>                       | <b>mg/L</b>      | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>pH</b>                                   |                  | <b>7.86</b> | <b>7.87</b>                        | <b>6.5</b>                               | <b>8.0</b>                               |
| <b>Phosphorus (Total)</b>                   | <b>mg/L-P</b>    | <b>0.03</b> | <b>0.03</b>                        | <b>-</b>                                 | <b>0.5</b>                               |
| <b>Total Suspended Solids</b>               | <b>mg/L</b>      | <b>1.00</b> | <b>2.00</b>                        | <b>-</b>                                 | <b>10</b>                                |

**Key Performance Indicators - 1st of the Year to End of the Month**

| <b>Key Performance Indicators - 1st of the Year to End of the Month</b> |                  |             |                                    |                                          |                                          |
|-------------------------------------------------------------------------|------------------|-------------|------------------------------------|------------------------------------------|------------------------------------------|
|                                                                         |                  | <b>From</b> | <b>1/01/2018</b>                   | <b>To</b>                                | <b>31/01/2018</b>                        |
|                                                                         | <b>Unit</b>      | <b>Last</b> | <b>90 Percentile Concentration</b> | <b>MIN (90 Percentile Concentration)</b> | <b>MAX (90 Percentile Concentration)</b> |
| <b>BOD</b>                                                              | <b>mg/L</b>      | <b>2.00</b> | <b>3.00</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Chlorine (Free Residual)</b>                                         | <b>mg/L</b>      | <b>0.02</b> | <b>0.02</b>                        | <b>-</b>                                 | <b>0.1</b>                               |
| <b>Faecal Coliforms</b>                                                 | <b>CFU/100ml</b> | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>150</b>                               |
| <b>Nitrogen (Ammonia)</b>                                               | <b>mg/L-N</b>    | <b>0.02</b> | <b>0.02</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>Nitrogen (Total)</b>                                                 | <b>mg/L-N</b>    | <b>5.29</b> | <b>5.29</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Oil and Grease</b>                                                   | <b>mg/L</b>      | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>pH</b>                                                               |                  | <b>7.86</b> | <b>7.87</b>                        | <b>6.5</b>                               | <b>8.0</b>                               |
| <b>Phosphorus (Total)</b>                                               | <b>mg/L-P</b>    | <b>0.03</b> | <b>0.03</b>                        | <b>-</b>                                 | <b>0.5</b>                               |
| <b>Total Suspended Solids</b>                                           | <b>mg/L</b>      | <b>1.00</b> | <b>2.00</b>                        | <b>-</b>                                 | <b>10</b>                                |

**Key Performance Indicators - Monthly**

| <b>Key Performance Indicators - Monthly</b> |                  |             |                                    |                                          |                                          |
|---------------------------------------------|------------------|-------------|------------------------------------|------------------------------------------|------------------------------------------|
|                                             |                  | <b>From</b> | <b>1/02/2018</b>                   | <b>To</b>                                | <b>28/02/2018</b>                        |
|                                             | <b>Unit</b>      | <b>Last</b> | <b>90 Percentile Concentration</b> | <b>MIN (90 Percentile Concentration)</b> | <b>MAX (90 Percentile Concentration)</b> |
| <b>BOD</b>                                  | <b>mg/L</b>      | <b>1.00</b> | <b>3.00</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Chlorine (Free Residual)</b>             | <b>mg/L</b>      | <b>0.02</b> | <b>0.04</b>                        | <b>-</b>                                 | <b>0.1</b>                               |
| <b>Faecal Coliforms</b>                     | <b>CFU/100ml</b> | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>150</b>                               |
| <b>Nitrogen (Ammonia)</b>                   | <b>mg/L-N</b>    | <b>0.01</b> | <b>0.03</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>Nitrogen (Total)</b>                     | <b>mg/L-N</b>    | <b>4.77</b> | <b>5.92</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Oil and Grease</b>                       | <b>mg/L</b>      | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>pH</b>                                   |                  | <b>7.60</b> | <b>7.90</b>                        | <b>6.5</b>                               | <b>8.0</b>                               |
| <b>Phosphorus (Total)</b>                   | <b>mg/L-P</b>    | <b>0.03</b> | <b>0.21</b>                        | <b>-</b>                                 | <b>0.5</b>                               |
| <b>Total Suspended Solids</b>               | <b>mg/L</b>      | <b>4.00</b> | <b>4.00</b>                        | <b>-</b>                                 | <b>10</b>                                |

**Key Performance Indicators - 1st of the Year to End of the Month**

| <b>Key Performance Indicators - 1st of the Year to End of the Month</b> |                  |             |                                    |                                          |                                          |
|-------------------------------------------------------------------------|------------------|-------------|------------------------------------|------------------------------------------|------------------------------------------|
|                                                                         |                  | <b>From</b> | <b>1/01/2018</b>                   | <b>To</b>                                | <b>28/02/2018</b>                        |
|                                                                         | <b>Unit</b>      | <b>Last</b> | <b>90 Percentile Concentration</b> | <b>MIN (90 Percentile Concentration)</b> | <b>MAX (90 Percentile Concentration)</b> |
| <b>BOD</b>                                                              | <b>mg/L</b>      | <b>1.00</b> | <b>3.00</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Chlorine (Free Residual)</b>                                         | <b>mg/L</b>      | <b>0.02</b> | <b>0.03</b>                        | <b>-</b>                                 | <b>0.1</b>                               |
| <b>Faecal Coliforms</b>                                                 | <b>CFU/100ml</b> | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>150</b>                               |
| <b>Nitrogen (Ammonia)</b>                                               | <b>mg/L-N</b>    | <b>0.01</b> | <b>0.03</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>Nitrogen (Total)</b>                                                 | <b>mg/L-N</b>    | <b>4.77</b> | <b>5.91</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Oil and Grease</b>                                                   | <b>mg/L</b>      | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>pH</b>                                                               |                  | <b>7.60</b> | <b>7.89</b>                        | <b>6.5</b>                               | <b>8.0</b>                               |
| <b>Phosphorus (Total)</b>                                               | <b>mg/L-P</b>    | <b>0.03</b> | <b>0.16</b>                        | <b>-</b>                                 | <b>0.5</b>                               |
| <b>Total Suspended Solids</b>                                           | <b>mg/L</b>      | <b>4.00</b> | <b>4.00</b>                        | <b>-</b>                                 | <b>10</b>                                |



## Key Performance Indicators - Monthly

| Key Performance Indicators - Monthly |           |      |                             |                                   |                                   |
|--------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                      |           | From | 1/03/2018                   | To                                | 31/03/2018                        |
|                                      | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                  | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)             | mg/L      | 0.02 | 0.03                        | -                                 | 0.1                               |
| Faecal Coliforms                     | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                   | mg/L-N    | 0.01 | 0.02                        | -                                 | 2                                 |
| Nitrogen (Total)                     | mg/L-N    | 5.22 | 5.22                        | -                                 | 10                                |
| Oil and Grease                       | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                   |           | 7.95 | 7.95                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                   | mg/L-P    | 0.04 | 0.07                        | -                                 | 0.5                               |
| Total Suspended Solids               | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |

## Key Performance Indicators - 1st of the Year to End of the Month

| Key Performance Indicators - 1st of the Year to End of the Month |           |      |                             |                                   |                                   |
|------------------------------------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                                                  |           | From | 1/01/2018                   | To                                | 31/03/2018                        |
|                                                                  | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                                              | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |
| Chlorine (Free Residual)                                         | mg/L      | 0.02 | 0.04                        | -                                 | 0.1                               |
| Faecal Coliforms                                                 | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                                               | mg/L-N    | 0.01 | 0.03                        | -                                 | 2                                 |
| Nitrogen (Total)                                                 | mg/L-N    | 5.22 | 5.91                        | -                                 | 10                                |
| Oil and Grease                                                   | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                                               |           | 7.95 | 7.93                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                                               | mg/L-P    | 0.04 | 0.16                        | -                                 | 0.5                               |
| Total Suspended Solids                                           | mg/L      | 1.00 | 4.00                        | -                                 | 10                                |

## Key Performance Indicators - Monthly

| Key Performance Indicators - Monthly |           |      |                             |                                   |                                   |
|--------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                      |           | From | 1/04/2018                   | To                                | 30/04/2018                        |
|                                      | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                  | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)             | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                     | CFU/100ml | 0.50 | 1.00                        | -                                 | 150                               |
| Nitrogen (Ammonia)                   | mg/L-N    | 0.02 | 0.05                        | -                                 | 2                                 |
| Nitrogen (Total)                     | mg/L-N    | 5.43 | 5.43                        | -                                 | 10                                |
| Oil and Grease                       | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                   |           | 7.82 | 7.82                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                   | mg/L-P    | 0.06 | 0.11                        | -                                 | 0.5                               |
| Total Suspended Solids               | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |

## Key Performance Indicators - 1st of the Year to End of the Month

| Key Performance Indicators - 1st of the Year to End of the Month |           |      |                             |                                   |                                   |
|------------------------------------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                                                  |           | From | 1/01/2018                   | To                                | 30/04/2018                        |
|                                                                  | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                                              | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |
| Chlorine (Free Residual)                                         | mg/L      | 0.02 | 0.03                        | -                                 | 0.1                               |
| Faecal Coliforms                                                 | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                                               | mg/L-N    | 0.02 | 0.03                        | -                                 | 2                                 |
| Nitrogen (Total)                                                 | mg/L-N    | 5.43 | 5.89                        | -                                 | 10                                |
| Oil and Grease                                                   | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                                               |           | 7.82 | 7.90                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                                               | mg/L-P    | 0.06 | 0.11                        | -                                 | 0.5                               |
| Total Suspended Solids                                           | mg/L      | 1.00 | 4.00                        | -                                 | 10                                |

**Key Performance Indicators - Monthly**

| <b>Key Performance Indicators - Monthly</b> |                  |             |                                    |                                          |                                          |
|---------------------------------------------|------------------|-------------|------------------------------------|------------------------------------------|------------------------------------------|
|                                             |                  | <b>From</b> | <b>1/05/2018</b>                   | <b>To</b>                                | <b>31/05/2018</b>                        |
|                                             | <b>Unit</b>      | <b>Last</b> | <b>90 Percentile Concentration</b> | <b>MIN (90 Percentile Concentration)</b> | <b>MAX (90 Percentile Concentration)</b> |
| <b>BOD</b>                                  | <b>mg/L</b>      | <b>1.00</b> | <b>1.00</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Chlorine (Free Residual)</b>             | <b>mg/L</b>      | <b>0.02</b> | <b>0.02</b>                        | <b>-</b>                                 | <b>0.1</b>                               |
| <b>Faecal Coliforms</b>                     | <b>CFU/100ml</b> | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>150</b>                               |
| <b>Nitrogen (Ammonia)</b>                   | <b>mg/L-N</b>    | <b>1.08</b> | <b>0.07</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>Nitrogen (Total)</b>                     | <b>mg/L-N</b>    | <b>6.09</b> | <b>6.09</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Oil and Grease</b>                       | <b>mg/L</b>      | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>pH</b>                                   |                  | <b>7.79</b> | <b>7.79</b>                        | <b>6.5</b>                               | <b>8.0</b>                               |
| <b>Phosphorus (Total)</b>                   | <b>mg/L-P</b>    | <b>0.03</b> | <b>0.14</b>                        | <b>-</b>                                 | <b>0.5</b>                               |
| <b>Total Suspended Solids</b>               | <b>mg/L</b>      | <b>1.00</b> | <b>1.00</b>                        | <b>-</b>                                 | <b>10</b>                                |

**Key Performance Indicators - 1st of the Year to End of the Month**

| <b>Key Performance Indicators - 1st of the Year to End of the Month</b> |                  |             |                                    |                                          |                                          |
|-------------------------------------------------------------------------|------------------|-------------|------------------------------------|------------------------------------------|------------------------------------------|
|                                                                         |                  | <b>From</b> | <b>1/01/2018</b>                   | <b>To</b>                                | <b>31/05/2018</b>                        |
|                                                                         | <b>Unit</b>      | <b>Last</b> | <b>90 Percentile Concentration</b> | <b>MIN (90 Percentile Concentration)</b> | <b>MAX (90 Percentile Concentration)</b> |
| <b>BOD</b>                                                              | <b>mg/L</b>      | <b>1.00</b> | <b>3.00</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Chlorine (Free Residual)</b>                                         | <b>mg/L</b>      | <b>0.02</b> | <b>0.02</b>                        | <b>-</b>                                 | <b>0.1</b>                               |
| <b>Faecal Coliforms</b>                                                 | <b>CFU/100ml</b> | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>150</b>                               |
| <b>Nitrogen (Ammonia)</b>                                               | <b>mg/L-N</b>    | <b>1.08</b> | <b>0.06</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>Nitrogen (Total)</b>                                                 | <b>mg/L-N</b>    | <b>6.09</b> | <b>6.01</b>                        | <b>-</b>                                 | <b>10</b>                                |
| <b>Oil and Grease</b>                                                   | <b>mg/L</b>      | <b>0.50</b> | <b>0.50</b>                        | <b>-</b>                                 | <b>2</b>                                 |
| <b>pH</b>                                                               |                  | <b>7.79</b> | <b>7.90</b>                        | <b>6.5</b>                               | <b>8.0</b>                               |
| <b>Phosphorus (Total)</b>                                               | <b>mg/L-P</b>    | <b>0.03</b> | <b>0.18</b>                        | <b>-</b>                                 | <b>0.5</b>                               |
| <b>Total Suspended Solids</b>                                           | <b>mg/L</b>      | <b>1.00</b> | <b>3.50</b>                        | <b>-</b>                                 | <b>10</b>                                |

## Key Performance Indicators - Monthly

| Key Performance Indicators - Monthly |           |      |                             |                                   |                                   |
|--------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                      |           | From | 1/06/2018                   | To                                | 30/06/2018                        |
|                                      | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                  | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |
| Chlorine (Free Residual)             | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                     | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                   | mg/L-N    | 0.02 | 1.12                        | -                                 | 2                                 |
| Nitrogen (Total)                     | mg/L-N    | 4.05 | 7.55                        | -                                 | 10                                |
| Oil and Grease                       | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                   |           | 7.48 | 7.48                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                   | mg/L-P    | 0.02 | 0.02                        | -                                 | 0.5                               |
| Total Suspended Solids               | mg/L      | 1.00 | 1.00                        | -                                 | 10                                |

## Key Performance Indicators - 1st of the Year to End of the Month

| Key Performance Indicators - 1st of the Year to End of the Month |           |      |                             |                                   |                                   |
|------------------------------------------------------------------|-----------|------|-----------------------------|-----------------------------------|-----------------------------------|
|                                                                  |           | From | 1/01/2018                   | To                                | 30/06/2018                        |
|                                                                  | Unit      | Last | 90 Percentile Concentration | MIN (90 Percentile Concentration) | MAX (90 Percentile Concentration) |
| BOD                                                              | mg/L      | 1.00 | 3.00                        | -                                 | 10                                |
| Chlorine (Free Residual)                                         | mg/L      | 0.02 | 0.02                        | -                                 | 0.1                               |
| Faecal Coliforms                                                 | CFU/100ml | 0.50 | 0.50                        | -                                 | 150                               |
| Nitrogen (Ammonia)                                               | mg/L-N    | 0.02 | 0.58                        | -                                 | 2                                 |
| Nitrogen (Total)                                                 | mg/L-N    | 4.05 | 6.82                        | -                                 | 10                                |
| Oil and Grease                                                   | mg/L      | 0.50 | 0.50                        | -                                 | 2                                 |
| pH                                                               |           | 7.48 | 7.90                        | 6.5                               | 8.0                               |
| Phosphorus (Total)                                               | mg/L-P    | 0.02 | 0.18                        | -                                 | 0.5                               |
| Total Suspended Solids                                           | mg/L      | 1.00 | 3.50                        | -                                 | 10                                |